

DIVISION: 07 00 00 – THERMAL AND MOISTURE PROTECTION

Section: 07 21 00 – Thermal Insulation

Section: 07 21 19 – Foamed-In-Place Insulation

REPORT HOLDER:

Creative Polymer Solutions LLC

2720 Southeastern Circle

Birmingham, AL 35215

www.creativepolymer.com

REPORT SUBJECT:

Accufoam OC Spray-applied Polyurethane Foam Insulation

1.0 SCOPE OF EVALUATION

1.1 This Research Report addresses compliance with the following Codes:

- 2021, 2018 and 2015 *International Building Code*® (IBC)
- 2021, 2018 and 2015 *International Residential Code*® (IRC)
- 2021, 2018 and 2015 *International Energy Conservation Code*® (IECC)

NOTE: This report references 2021 Code sections. Section numbers for earlier Code editions may differ.

1.2 Accufoam OC insulation has been evaluated for the following properties (see Table 1):

- Surface-burning characteristics
- Physical properties
- Thermal resistance

1.3 Accufoam OC insulation has been evaluated for the following uses (see Table 1):

- Use as nonstructural thermal insulation on or in interior and exterior walls, floors, and underside of roofs
- Alternatives to Code-prescribed thermal barriers
- Alternatives to Code-prescribed ignition barriers
- Use in the exterior walls of Type V construction

2.0 STATEMENT OF COMPLIANCE

Accufoam OC insulation complies with the Codes listed in Section 1.1, for the properties stated in Section 1.2 and uses stated in Section 1.3, when installed as described in this report, including the Conditions of Use stated in Section 6.

3.0 DESCRIPTION

3.1 Materials:

3.1.1 Accufoam OC Insulation: Accufoam OC insulation is a semi-rigid, open-cell, polyurethane foam plastic. The insulation is a two-component spray foam plastic with a nominal in-place density of 0.5 pounds per cubic foot. The insulation is produced in the field by combining a polymeric isocyanate (A component) with a resin (B component). The insulation liquid components are supplied in 55-gallon drums and must be stored at temperatures between 65°F and 95°F. The resin (B component) must be protected from freezing temperatures and has a shelf life of six months.

3.2 Intumescent Coatings:

3.2.1 DC315 Intumescent Coating: DC315 intumescent coating is a water-based coating manufactured by IFTI, Paint to Protect, and is supplied in 5-gallon pails and 55-gallon drums. The coating material has a shelf life of 24 months when stored in factory-sealed containers at temperatures between 41°F and 95°F. DC315 complies with ICC-ES AC456 as recognized in IAPMO ER-0499.

4.0 Performance Characteristics:

4.1 Surface-burning Characteristics: Accufoam OC insulation, at a maximum thickness of 4 inches and a nominal density of 0.5 pcf, has a flame-spread index of 25 or less and a smoke developed index of 450 or less, when tested in accordance with ASTM E84. Based on large scale tests in accordance with NFPA 286 and ICC-ES AC377 Appendix X, the insulation can be installed at greater thicknesses as described in Sections 5.3 and 5.4. When the insulation is separated from the interior living space of the



building with minimum 1/2-inch-thick gypsum board, the maximum insulation thickness is not limited. A thermal barrier of minimum 25/32-inch-thick wood structural panel is also permitted, and the maximum insulation thickness is not limited.

4.2 Thermal Resistance, R-values: Accufoam OC insulation has thermal resistance (R-value) at a mean temperature of 75°F as shown in Table 2.

5.0 INSTALLATION

5.1 General:

Accufoam OC insulation must be installed in accordance with the manufacturer's published installation instructions, the applicable Code, and this Research Report. The installation requirements in Sections 5.1 through 5.4 apply to all Types of construction. A copy of the manufacturer's instructions must be available on the jobsite during installation.

5.2 Application:

Accufoam OC insulation is spray-applied on the jobsite using a volumetric positive displacement pump as identified in the manufacturer's application instructions. The insulation must be applied when the ambient temperature is greater than 14°F. The insulation must not be used in areas that have a maximum in-service temperature greater than 180°F. The foam plastic must not be used in electrical outlet or junction boxes or in contact with water, rain, or soil. The foam plastic must not be sprayed onto a substrate that is wet, or covered with frost or ice, loose scales, rust, oil, or grease. The insulation must be protected from the weather during and after application. The insulation may be applied to a maximum thickness of 5-1/2 inches per pass. A minimum of 20 minutes must be allowed between applications of material.

5.3 Thermal Barrier:

5.3.1 Application with a Prescriptive Thermal Barrier: Accufoam OC insulation must be separated from the interior living space of the building by an approved thermal barrier of 1/2-inch-thick gypsum board or an equivalent 15 minute thermal barrier complying with, and installed in accordance with, IBC Section 2603.4 or IRC Section R316.4, as applicable. Exceptions are provided in Sections 5.3.2 and 5.4.

When the insulation is separated from the interior living space of the building with minimum 1/2-inch-thick gypsum board, the maximum thickness is not limited. A thermal barrier of 25/32-inch-thick wood structural panel is also permitted, and the maximum insulation thickness is unlimited.

5.3.2 Application without a Prescriptive Thermal Barrier:

Accufoam OC insulation may be installed without the 15-minute thermal barrier prescribed in IBC Section 2603.4 and IRC Section R316.4, when installed as described in this section. The insulation must be a maximum of 8 inches on walls and 14 inches on ceilings and be covered on all surfaces with DC315 applied at 18 wet mils (1.13 gal/100 ft²).

The coating must be applied over the insulation in accordance with the coating manufacturer's instructions and this report. Surfaces to be coated must be dry, clean, and free of dirt, loose debris and other substances that could interfere with adhesion of the coating. The coating is applied with low-pressure airless spray equipment.

5.4 Attics and Crawl Spaces:

Accufoam OC insulation may be applied in attics and crawl spaces as described in either 5.4.1 or 5.4.2. When the insulation is installed in an attic or crawlspace in accordance with this section, a thermal barrier is not required between the insulation and the attic or crawl space but is required between the insulation and the interior living space.

5.4.1 Application with a Prescriptive Ignition Barrier: When Accufoam OC insulation is installed within attics and crawl spaces where entry is made only for service of utilities, the ignition barrier must be installed in accordance with IBC Section 2603.4.1.6, or IRC Section R316.5.3 or R316.5.4, as applicable. The ignition barrier must be consistent with the requirements for the type of construction required by the applicable Code and must be installed in a manner, so the foam plastic insulation is not exposed.

5.4.2 Application without a Prescriptive Ignition Barrier:

5.4.2.1 General: Accufoam OC insulation may be installed in attics and crawl spaces as described in Sections 5.4.2.2, 5.4.2.3 and 5.4.2.4, without the ignition barrier prescribed in IBC Section 2603.4.1.6 and IRC Sections R316.5.3 and R316.5.4, subject to the following conditions:



Intertek



PCA-101



- a. Entry to the attic or crawl space is only to service utilities, and no storage is permitted.
- b. There are no interconnected attic or crawl space areas.
- c. Air in the attic or crawl space is not circulated to other parts of the building.
- d. Under-floor (crawl space) ventilation is provided when required by IBC Section 1202.4 or IRC Section R408.1, as applicable.
- e. Attic ventilation is provided when required by IBC Section 1202.2.1 or IRC Section R806.
- f. Combustion air is provided in accordance with IMC (International Mechanical Code) Section 701.

5.4.2.2 Attics and Crawl Spaces: The insulation must be a maximum of 8 inches on walls and 14 inches on ceilings and be covered on all surfaces with DC315 applied at 4 wet mils (0.25 gal/100 ft²).

5.4.2.3 Unvented Attics: Creative Polymer Solutions has conducted end use configuration testing (per IBC Section 2603.9 and IRC Section R316.6) and analysis to qualify the use of Accufoam OC insulation without a prescriptive ignition barrier or intumescent coating in unvented attics conforming with IBC Section 1202.3 or IRC Section R806.5. The testing and analysis are described in Priest & Associates EEV 10778B dated June 16, 2020. The conclusions of that evaluation are as follows: When Accufoam OC insulation is applied in unvented attics conforming to IBC Section 1202.3 or IRC Section R806.5, the insulation may be applied to the underside of roof sheathing and/or rafters and to vertical surfaces to a minimum thickness of 3 inches. Rafters may be left without foam coverage or may be covered with foam up to the maximum thickness allowed. Maximum thickness on the underside of roof sheathing or on vertical wall surfaces is 18 inches. The insulation may be left exposed to the attic without a prescriptive ignition barrier or an intumescent coating. The attic must have attic access complying with IRC Section R807, horizontally placed in the attic floor and opening outward toward the living space. For items penetrating the roof deck or walls, such as skylight wells or vents, the penetrating item exposed in the attic must be covered with a minimum of 3 inches of Accufoam OC insulation.

5.4.2.4 Use on Attic Floors: Accufoam OC insulation may be installed exposed at a maximum thickness of 8 inches between and over the joists in attic floors. The insulation must be separated from the interior of the building by 1/2-

inch gypsum or an approved thermal barrier. The insulation may be installed without the prescriptive ignition barrier required by IBC Section 2603.4.1.6 or IRC Section R316.5.3 and R316.5.4 when covered with DC315 as described in Section 5.4.2.2.

6.0 CONDITIONS OF USE

Accufoam OC spray-applied foam plastic insulation described in this Research Report complies with, or is a suitable alternative to, what is specified in those Codes listed in Section 1.0 of this report, subject to the following conditions:

6.1 Installation must comply with this Research Report, the manufacturer's published installation instructions, and the applicable Code. In the event of a conflict between the manufacturer's instructions and this report, this report governs.

6.2 The insulation must be separated from the interior living space of the building by a thermal barrier as described in Section 5.3.

6.3 The insulation must not exceed the thicknesses noted in Sections 4.1, 5.3, and 5.4, as applicable.

6.4 The insulation must be applied by contractors approved by Creative Polymer Solutions LLC.

6.5 When Accufoam OC insulation is installed under the conditions of Section 5.4.2.3 of this report, the following conditions apply:

6.5.1 Since the performance of Accufoam OC, when installed in unvented attics without a Code-prescribed ignition barrier or an intumescent coating, is based on fire performance of an unvented attic, the installation must be approved by the Code official. The installation must conform with the provisions of Section 5.4.2.3 and Conditions a. through c., and Condition f. of Section 5.4.2.1. A copy of the Priest & Associates Engineering Evaluation (referenced in Section 7.4) must be provided to the Code official upon request.

6.5.2 Signage shall be permanently affixed in the attic and shall be visible from all points within the attic. The sign shall state "*Caution, this is an unvented attic by design. No modification may be made to this unvented condition. The attic shall not be vented. Holes into the unvented attic shall be immediately repaired and sealed. Penetrations of the*





ceiling or wall membrane between the unvented attic and living space, other than the horizontal access hatch, must be protected in an approved manner. This unvented attic shall not be used for storage. See Intertek Code Compliance Research Report CCCR-0371 on the Intertek Website."

6.6 The insulation must be installed with a vapor retarder when required by the applicable Code.

6.7 Use of the insulation in areas where the probability of termite infestation is "very heavy" must be in accordance with IRC Section R318.4 or IBC Section 2603.8, as applicable.

6.8 Jobsite certification and labeling of the insulation must comply with IRC Section N1101.10, N1101.14 and IECC Section C303.1 or R303.1 and R401.3, as applicable.

6.9 The insulation is produced under a quality control program with inspections by Intertek Testing Services NA, Inc.

7.0 SUPPORTING EVIDENCE

7.1 Reports of tests in accordance with ASTM C518, ASTM E84, and NFPA 286.

7.2 Data in accordance with the ICC-ES Acceptance Criteria for Spray-applied Foam Plastic Insulation (AC377), dated February 2020, including reports of tests in accordance with Appendix X.

7.3 Data in accordance with ICC 1100-2019.

7.4 Priest & Associates Engineering Evaluation 10778B, dated June 16, 2020, entitled "For Inclusion of Accufoam OC SPF Insulation in Unventilated Attics without an Ignition Barrier in an Intertek CCRR."

7.5 Research Reports for evaluation of data in accordance with ICC-ES Acceptance Criteria for Fire-protective Coatings Applied to Spray-applied Foam Plastic Insulation Installed

without a Code-prescribed Thermal Barrier (AC456), dated October 2015.

7.6 Intertek Listing Report "Creative Polymer Solutions – Accufoam OC Spray-applied Polyurethane Foam Plastic Insulation".

8.0 IDENTIFICATION

The A and B components of the insulation described in this Research Report are identified with the manufacturer’s name (Creative Polymer Solutions LLC), address and telephone number; the product name (Accufoam OC); use instructions; the flame spread and smoke-developed indices; the lot number; the Intertek Mark, and the Code Compliance Research Report number (CCRR-0371).



9.0 OTHER CODES

This section does not apply.

10.0 CODE COMPLIANCE RESEARCH REPORT USE

10.1 Approval of building products and/or materials can only be granted by a building official having legal authority in the specific jurisdiction where approval is sought.

10.2 Code Compliance Research Reports shall not be used in any manner that implies an endorsement of the product by Intertek Testing.

10.3 Reference to <https://bpdirectory.intertek.com> is recommended to ascertain the current version and status of this report.

This Code Compliance Research Report ("Report") is for the exclusive use of Intertek’s Client and is provided pursuant to the agreement between Intertek and its Client. Intertek’s responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Report. Only the Client is authorized to permit copying or distribution of this Report and then only in its entirety, and the Client shall not use the Report in a misleading manner. Client further agrees and understands that reliance upon the Report is limited to the representations made therein. The Report is not an endorsement or recommendation for use of the subject and/or product described herein. This Report is not the Intertek Listing Report covering the subject product and utilized for Intertek Certification and this Report does not represent authorization for the use of any Intertek certification marks. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.





TABLE 1 – PROPERTIES EVALUATED

PROPERTY	2021 IBC SECTION ¹	2021 IRC SECTION ¹	2021 IECC SECTION ¹
Physical properties	Not required	Not required	Not required
Surface-burning characteristics	2603.3	R316.3	Not applicable
Thermal barrier/ignition barrier	2603.4	R316.4	Not applicable
Thermal resistance	1301	N1101.10 N1102	C303.1.1 C303.1.2 C303.1.4 R303.1.1 R303.1.2 R303.1.4

¹ Section numbers may be different for earlier versions of the International Codes.

TABLE 2 – THERMAL RESISTANCE (R Values)^{1,2,3}

THICKNESS (inches)	R-VALUE (°F.ft ² .h/Btu)
1	3.7
2	7.2
3	11
3.5	12
12	41

¹ R-values are calculated based on tested K-values at 1 inch and 3.5 inch thicknesses.

² R-values greater than 10 are rounded to the nearest whole number.

³ To determine R values for thickness not listed:

- a. Between 1 inch and 3.5 inch can be determined through linear interpolation or
- b. Greater than 3.5 inches can be calculated based on R= 3.4/inch

